



Product Information Bulletin

P.O. Box 467 | 64 Outwater Lane, Garfield, NJ 07026 Ph: 973-340-7889 | Fax: 973-340-7809

System #2 Pipe Markers



Compliance:

- ANSI / ASME A13.1-2007 "Scheme for the Identification of Piping Systems"
- ANSI Z535.1 "Safety Color Code"

SIZE CHART

MARKER STYLE	OUTSIDE PIPE DIAMETER	MARKER DIMENSIONS	SIZE OF LETTERS
Small	3/4" - 2 3/8"	8 x 1 1/2"	3/4 inch
Large	2 1/2" - 7 7/8"	14 x 2 1/4"	1 1/4 inch

Standard Colors:

• Flammable Fluids	• Potable, Cooling, Boiler Feed & Other Water	• Compressed Air	• Fire Quenching Fluids	• Toxic & Corrosive Fluids
• Combustible Fluids	• Defined by User	• Defined by User	• Defined by User	• Defined by User

Material:

Outdoor Grade 3.2 mil thick high gloss adhesive backed calendared vinyl film, printed using UV and chemical resistant inks, to insure durability in most commercial / industrial environments.

Use:

Identify piping systems. Pipe Markers and Arrows are provided in conventional rolls of 50. Rolls are slitted between each marker and arrow to allow for easy installation of the arrow in any direction.

Adhesive:

Aggressive Acrylic Adhesive formulated to adhere to a variety of insulated and non insulated pipe surfaces.

Surface Preparation:

Surface must be dry and reasonably clean prior to applying adhesive backed label product. Minimum Surface Temperature 50° F.

Outdoor Durability: 4 to 5 years Mid Continental US

Abrasion Resistance: Good

Water Resistance: Good

Solvent Resistance: Good

Service Temp: -20°F (-29°C) to 200°F (93°C)

Storage Stability: 2 years at 70°F with 50 RH

DATE: ___ / ___ / ___

JOB: _____

CONTRACTOR: _____