



## Product Information Bulletin

64 Outwater Lane, Garfield, NJ 07026 Ph: 973-340-7889 | Fax: 973-340-7809

# Fire/Sprinkler Signs

THIS VALVE  
SUPPLY TO AUTOMATIC  
**ALARM LINE**

**MUST BE OPEN**

TO BE HANDLED ONLY BY AUTHORIZED PERSONS OR BY EMPLOYEE CARING FOR SPRINKLER SYSTEMS

**IN CASE OF FIRE DO NOT SHUT VALVE UNTIL FIRE IS ENTIRELY OUT**

WHEN VALVE IS SHUT FOR EMERGENCY REPAIRS OR FIRE NOTIFY:

REQUEST DIRECTIONS-RESTORE PROTECTION QUICKLY

SPR-2  
7 3/4" x 9"

**HYDRAULIC-SYSTEM**

THIS BUILDING IS PROTECTED BY A HYDRAULICALLY DESIGNED AUTOMATIC SPRINKLER SYSTEM

Location: \_\_\_\_\_

No. of Sprinklers: \_\_\_\_\_

Basis of Design

1. Density: \_\_\_\_\_ GPM/SG. FT.

2. Designed Area of Discharge: \_\_\_\_\_ SQ. FT.

System Demand

1. GPM Discharge: \_\_\_\_\_ GPM

2. Residual Pressure at the Base of the Riser: \_\_\_\_\_ PSI

3. Hose Stream Allowance: \_\_\_\_\_

Occupancy Classification: \_\_\_\_\_

Commodity Classification: \_\_\_\_\_

Maximum Storage Height: \_\_\_\_\_

Date of Installation: \_\_\_\_\_

Installed By: \_\_\_\_\_

SPR-16  
5 x 7" | 7" x 10"

**HYDRAULIC-SYSTEM**

This system as shown on \_\_\_\_\_

company print # \_\_\_\_\_ dated \_\_\_\_\_

for \_\_\_\_\_

at \_\_\_\_\_

is designed to discharge at a rate of \_\_\_\_\_ gpm

(L/min) per sq ft (m<sup>2</sup>) of floor area over a maximum area of \_\_\_\_\_ sq ft (m<sup>2</sup>) when supplied

with water at the rate of \_\_\_\_\_ gpm (L/min)

at \_\_\_\_\_ psi (bars) at the base of the riser,

Hose stream allowance of \_\_\_\_\_ gpm (L/min)

is included in the above.

Occupancy classification: \_\_\_\_\_

Commodity classification: \_\_\_\_\_

Maximum storage height: \_\_\_\_\_

Installed by: \_\_\_\_\_

SPR-17  
5 x 7" | 7" x 10"

**ANTI-FREEZE SYSTEM**

The sprinkler system in this building is made up of one or more systems containing an anti-freeze solution for protection against freezing.

Type of Anti-Freeze: \_\_\_\_\_

Manufacturer: \_\_\_\_\_

Trade Name or Brand: \_\_\_\_\_

Solution Concentration: \_\_\_\_\_ %

System Volume: \_\_\_\_\_ gallons

Protected to: \_\_\_\_\_ degrees (F/C)

Location: \_\_\_\_\_

SPR-18  
5 x 7" | 7" x 10"

**SPRINKLER FIRE-ALARM**

WHEN BELL RINGS CALL FIRE DEPT or POLICE

SPR-20  
7 x 5" | 10 x 7"

**CONTROL VALVE**

This valve controls fire protection equipment. Do not close until after fire has been extinguished.

Use auxiliary valves when necessary to shut off supply to auxiliary equipment.

**CAUTION**

Automatic alarm may be sounded if this valve is closed.

SPR-21  
7 x 5" | 10 x 7"

## Sprinkler Plates

**ALARM LINE**

SPR-3  
6" x 2"

**ALARM TEST**

SPR-4  
6" x 2"

**AUXILIARY DRAIN**

SPR-5  
6" x 2"

**CONTROL VALVE**

SPR-6  
6" x 2"

**DRAIN**

SPR-7  
6" x 2"

**FILLING LINE**

SPR-8  
6" x 2"

**ANTI-FREEZE SYSTEM**

SPR-9  
6" x 2"

**INSPECTORS TEST**

SPR-10  
6" x 2"

**MAIN CONTROL**

SPR-11  
6" x 2"

**MAIN DRAIN**

SPR-12  
6" x 2"

**SHUT-OFF VALVE**

SPR-13  
6" x 2"

**WATER MOTOR LINE**

SPR-14  
6" x 2"

**TEST & DRAIN**

SPR-22  
6" x 2"

**AIR LINE**

SPR-23  
6" x 2"

**AIR CONTROL**

SPR-24  
6" x 2"

**MAIN DRAIN**

25752  
6" x 2"

**DRAIN VALVE**

25750  
6" x 2"

**INSPECTORS TEST**

25758  
6" x 2"

### Product Description:

Sprinkler system plates comply with the National Board of Fire Underwriters (NFBU) Standard No. 13. Line plates can be used throughout the piping system as markers or applied as valve tags.

### Materials:

- .020" thick Rust Free White Aluminum
- Aluminum does not rust or break, graded for outdoor use.
- 4 pre-drilled holes @ 0.218" and Square Corners
- Printed with UV Resistant Inks

**Temp Range:** -40°F to 212°F

**DATE:** / /

**JOB:** \_\_\_\_\_

**CONTRACTOR:** \_\_\_\_\_